

UDC



**NATIONAL STANDARD OF THE PEOPLE'S REPUBLIC
OF CHINA**

中华人民共和国国家标准

GB 50116-1998

Code for design of automatic fire alarm system

火灾自动报警系统设计规范

GB50116-1998

Prepared by: Ministry of Public Security of the People's Republic of China

Approved by: Ministry of Construction of the People's Republic of China

Implemented as of: June 1, 1999

Beijing 1999

NOTICE

This code is written in Chinese and English. The Chinese text shall be taken as the ruling one in the event of any inconsistency between the Chinese text and the English text.

Notice on Issuance of National Standard

"Code for Design of Automatic Fire Alarm System"

Jianbiao No.[1998J 245

As required by the "Plan for Preparation and Revision of Standards and Quotas for Construction Projects in 1994" from the State Planning Commission (Appendix 9 to document Ji Zonghe No. [1994] 240), the "Code for Design of Automatic Fire Alarm System" has been revised by the Ministry of Public Security jointly with departments concerned, and been jointly reviewed by relevant departments, it is hereby approved that "Code for Design of Automatic Fire Alarm System" GB50116-98 be implemented as of June 1, 1999 as a compulsory national standard. The former "Code for Design of Automatic Fire Alarm System" GB116-88 shall be ceased and scrapped as of the same date.

This specification shall be governed by the Ministry of Public Security, be interpreted in detail by Shenyang Fire control Scientific Research institute of the Ministry of Public Security, and be published and distributed by the China Planning Publication House as organized by the Standard Quota Research Institute of the Ministry of Construction.

Ministry of Construction of the People's Republic of China December 7, 1998

Contents

1 General Provisions	5
2 Terminology	5
3 Classification of System Protection Objectives and Location of Fire detectors	7
3.1 Classification of system protection objectives	7
3.2 Locations of fire detectors	9
4 Division of Alarm Zones and Detection Zones	10
4.1 Division of alarm zones	10
4.2 Division of detection zones	10
5 System Design	11
5.1 General provisions	11
5.2 Selection of type and design requirements for system	11
5.3 Design requirements for linked fire fighting control	12
5.4 Fire emergency broadcasting	13
5.5 Fire alarm device	13
5.6 Telephone specific for fire control purpose	14
5.7 System grounding	15
6 Fire Prevention and Fighting Control Room and Linked Fire Fighting Control	16
6.1 General Provisions	16
6.2 Fire prevention and fighting control room	16
6.3 Functions of fire prevention control devices	17
7 Selection of Fire Detectors	20
7.1 General provisions	20
7.2 Selection of point type Fire detectors	20
7.3 Selection of line type fire detectors	23
8 Provision of Fire Detectors and Manual Fire Alarm Pushbuttons	24
8.1 Number and locating of point type fire detectors	24
8.2 Provision of line fire detectors	26
8.3 Provision of manual fire alarm pushbuttons	27
9 Power Supply for the System	27
10 Wiring	28
10.1 General provisions	28
10.2 Indoor wiring	28
Appendix A Limit Curves for Detector Mounting Spacing	30
Appendix B Influence on Provision of Detectors by Room Beams of Different Heights	31
Appendix C Number of Inter-beam Intervals to be Protected by One Detector as Determined by the Area Between Beams	32
Appendix D Suggested Locations of Fire Detectors	33
D.1 Special protection objectives	33
D.2 Class I protection objectives	33
D.3 Class II protection objectives	34
Appendix E Notes on Some Expressions Used in This Specification	37
Additional Notes	37

1 General Provisions

1.0.1 This specification has been formulated for the purpose to design automatic fire alarm systems in a reasonable manner, to prevent and reduce the fire hazard, and to protect the safety of people and properties.

1.0.2 This specification is applicable to the automatic fire alarm systems provided in the industrial and civilian buildings, but does not apply to the automatic fire alarm systems provided in locations for production and for storing gunpowder, dynamite, ammunition and firing articles.

1.0.3 The design of automatic fire alarm systems must follow the relevant policies of the state, be aimed at the characteristics of the objects to be protected, and be safe and practical, economic, adopting advanced technologies and in a reasonable structure.

1.0.4 The design of automatic fire alarm systems shall, in addition to the implementation of this specification, comply with the stipulations in the relevant compulsory national standards and specifications currently in force.

2 Terminology

2.0.1 Alarm zone

The unit of the guarding scope of the automatic fire alarm system as being divided according to the fire prevention zoning or floor

2.0.2 Detection zone

The unit of an alarm zone as being divided according to the location for fire detection

2.0.3 Monitoring area

The effective detecting area of one fire detector

2.0.4 Spacing

The horizontal distance between the centers of two adjacent fire detectors

2.0.5 Monitoring radius

The maximum horizontal distance in one direction that can be effectively covered by one fire detector

2.0.6 Local alarm system

A automatic fire alarm system with simple functions consisting of the local fire alarm controllers and the fire detectors, or of the fire alarm controllers and fire detectors.

完整版本请在线下单

或咨询：

TEL: 400-678-1309

QQ: 19315219

Email: info@lancarver.com

<http://www.lancarver.com>

线下付款方式：

1. 对公账户：

单位名称：北京文心雕语翻译有限公司

开户行：中国工商银行北京清河镇支行

账 号：0200 1486 0900 0006 131

2. 支付宝账户：info@lancarver.com

注：付款成功后，请预留电邮，完整版本将在一个工作日内通过电子 PDF 或 Word 形式发送至您的预留邮箱，如需索取发票，下单成功后的三个工作日内安排开具并寄出，预祝合作愉快！



银联特约商户